ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

C E R T I F I C A T E

No. Z2 001783 0001 Rev. 08

Holder of Certificate: **Dongying Dahai Kelin Solar Power Co., Ltd**
Yankou Village, Daozhuang Town, Guangrao County
257336 Dongying City, Shandong Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 882161819011

Valid until: 2029-08-12

Date, 2026-04-22

(Xinlian LUO)

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

C E R T I F I C A T E

No. Z2 001783 0001 Rev. 08

Model(s):

1000V DC Single Glass Module Types
DHM60-XXX (XXX=275-315, in steps of 5)
DHM72-XXX (XXX=335-380, in steps of 5)
DHM60H-XXX (XXX=285-325, in steps of 5)
DHM72H-XXX (XXX=345–395, in steps of 5)
DHM72T20-xxx/MR (XXX=435-455, in steps of 5)
DHM72T30-XXX/MR (XXX=535-550, in steps of 5)
DHM60T20-XXX/MR (XXX=365-380, in steps of 5)
DHM60T30-XXX/MR (XXX=445-460, in steps of 5)
DHM54T30-XXX/MR (XXX=390-415, in steps of 5)
DHM72T25-XXX/MR (XXX=435-455, in steps of 5)
DHM60T25-XXX/MR (XXX=365-380, in steps of 5)
1500V DC Double Glass Module Types:
DHM72D20-XXX/MR (XXX=445-460, in steps of 5)
DHM72D30-XXX/MR (XXX=535-555, in steps of 5)
DHM60D20-XXX/MR (XXX=370-385, in steps of 5)
DHM60D30-XXX/MR (XXX=445-465, in steps of 5)
DHM66D50-XXX/MR (XXX=645-680, in steps of 5)
DHM60D50-XXX/MR (XXX=590-615, in steps of 5)
DHM55D50-XXX/MR (XXX=530-555, in steps of 5)
DHM50D50-XXX/MR (XXX=490-515, in steps of 5)
DHM72D30-XXX/TP (XXX=560-610, in steps of 5)
DHM72D35-XXX/TP (XXX=560-610, in steps of 5)
DHM66D30-XXX/TP (XXX=510-560, in steps of 5)
DHM66D35-XXX/TP (XXX=510-560, in steps of 5)
DHM60D30-XXX/TP (XXX=460-510, in steps of 5)
DHM60D35-XXX/TP (XXX=460-510, in steps of 5)
DHM54D30-XXX/MR (XXX=405-430, in steps of 5)
DHM54D35-XXX/MR (XXX=400-425, in steps of 5)
DHM54D30-XXX/TP (XXX=415-460, in steps of 5)
DHM54D35-XXX/TP (XXX=410-460, in steps of 5)
DHM66D60-XXX/TP (XXX=585-640, in steps of 5)
DHM60D60-XXX/TP (XXX=535-580, in steps of 5)
DHM48D60-XXX/TP (XXX=420-465, in steps of 5)
DHM66D65-XXX/TP (XXX=585-640, in steps of 5)
DHM60D65-XXX/TP (XXX=535-580, in steps of 5)
DHM48D65-XXX/TP (XXX=420-465, in steps of 5)
DHM66D30-XXX/MR (XXX=490-510, in steps of 5)
DHM66D35-XXX/MR (XXX=490-510, in steps of 5)
DHM60D35-XXX/MR (XXX=445-465, in steps of 5)
DHM50D50-XXX/TP (XXX=520-545, in steps of 5)
DHM55D50-XXX/TP (XXX=575-600, in steps of 5)
DHM60D50-XXX/TP (XXX=630-655, in steps of 5)
DHM66D50-XXX/TP (XXX=690-720, in steps of 5)
DHM78D30-XXX/TP (XXX=620-660, in steps of 5)
DHM78D35-XXX/TP (XXX=620-660, in steps of 5)
DHM54D60-XXX/TP (XXX=480-525, in steps of 5)
DHM54D65-XXX/TP (XXX=480-525, in steps of 5)
1500V DC Single Glass Module Types
DHM66T50-XXX/MR (XXX=645-670, in steps of 5)
DHM60T50-XXX/MR (XXX=585-610, in steps of 5)
DHM55T50-XXX/MR (XXX=530-555, in steps of 5)
DHM50T50-XXX/MR (XXX=485-510, in steps of 5)
DHM72T31-XXX/MR (XXX=535-550, in steps of 5)
DHM60T31-XXX/MR (XXX=445-460, in steps of 5)
DHM54T31-XXX/MR (XXX=390-415, in steps of 5)

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

C E R T I F I C A T E

No. Z2 001783 0001 Rev. 08

DHM54T35-XXX/MR (XXX=390-415, in steps of 5)
DHM60T35-XXX/MR (XXX=445-460, in steps of 5)
DHM72T35-XXX/MR (XXX=535-550, in steps of 5)
DHM54T31-XXX/TP (XXX=410-435, in steps of 5)
DHM60T31-XXX/TP (XXX=455-485, in steps of 5)
DHM72T31-XXX/TP (XXX=555-585, in steps of 5)
DHM54T35-XXX/TP (XXX=410-435, in steps of 5)
DHM60T35-XXX/TP (XXX=455-485, in steps of 5)
DHM72T35-XXX/TP (XXX=555-585, in steps of 5)
DHM66T31-XXX/MR (XXX=490-510, in steps of 5)
DHM66T31-XXX/TP (XXX=510-535, in steps of 5)
DHM66T35-XXX/MR (XXX=490-510, in steps of 5)
DHM66T35-XXX/TP (XXX=510-535, in steps of 5)
DHM66T60-XXX/TP (XXX=585-640, in steps of 5)
DHM60T60-XXX/TP (XXX=535-580, in steps of 5)
DHM48T60-XXX/TP (XXX=420-465, in steps of 5)
DHM66T65-XXX/TP (XXX=585-640, in steps of 5)
DHM60T65-XXX/TP (XXX=535-580, in steps of 5)
DHM48T65-XXX/TP (XXX=420-465, in steps of 5)
DHM54T60-XXX/TP (XXX=480-525, in steps of 5)
DHM54T65-XXX/TP (XXX=480-525, in steps of 5)
XXX is standing for rated output power at STC

Parameters:

Construction: Framed, with Junction box, Cable and Connectors
Test Laboratory: Tianjin CETC New Energy Research Institute Co., Ltd.
(NO.6 Huake seven RD, Haitai street, Xiqing District,Tianjin, 300384, China)
Safety Class: Class II
Maximum System Voltage: 1000V DC or 1500V DC
Fire Safety Class: Class C according to UL790

Tested according to:

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®